

ACCURACY (continued)

Thermocouple (TC)

TYPE	MEASUREMENT ACCURACY
K, J, T, E, L, U N, C, D S, B, R MoRe5-MoRe41	± 0.5 °C or 0.08% ^[1] ± 1.0 °C or 0.08% ^[1] ± 2.0 °C or 0.08% ^[1]
Influence of the internal reference junction	Pt100 ± (0.30 + 0.005 t) °C t = value of temperature without regard to sign °C

Voltage (mV)

TYPE	MEASUREMENT ACCURACY	MEASUREMENT RANGE
Millivolt (mV)	± 20 µV or 0.08% ^[1]	(-10 to 100) mV

General Accuracy

Influence of power supply	± 0.01%/V deviation from 24 V ^[2]
Load influence	± 0.02%/100 Ω ^[2]
Temperature drift	<p>Resistive thermometer (RTD): $T_d = \pm (15 \text{ ppm}/\text{°C} \times \text{range end value} + 50 \text{ ppm}/\text{°C} \times \text{measurement range}) \times \Delta\theta$</p> <p>Resistive thermometer Pt100: $T_d = \pm (15 \text{ ppm}/\text{°C} \times (\text{range end value} + 200) + 50 \text{ ppm}/\text{°C} \times \text{measurement range}) \times \Delta\theta$</p> <p>Thermocouple (TC): $T_d = \pm (50 \text{ ppm}/\text{°C} \times \text{range end value} + 50 \text{ ppm}/\text{°C} \times \text{measurement range}) \times \Delta\theta$</p> <p>$\Delta\theta$ = Deviation of the ambient temperature according to the reference condition</p>
Long term stability	≤ 0.1 °C/year ^[3] or ≤ 0.05%/year ^{[1][3]}

[1] % is related to the adjusted measurement range (the value to be applied is the greater)
[2] All data is related to a measurement end value of 20 mA
[3] Under reference conditions

INSTALLATION CONDITIONS

Ambient Conditions

Ambient temperature	(-40 to 85) °C [-40 to 185] °F
Storage temperature	(-40 to 100) °C [-40 to 212] °F
Climatic class	To EN 60 654-1, Class C
Moisture condensation	Allowable
Vibration protection	4 g / (2 to 150) Hz according to IEC 60 068-2-6
EMC immunity	Interference immunity and interference emission as per EN 61 326-1 (IEC 1326)